



Compliance Statement

Screened Class EA / Category 6A ISO/IEC, EN & ANSI/TIA Two Connector Channel


HCS KABLOLAMA SISTEMLERI SAN. ve TIC. A.Ş.
Ikitelli Osb.Mah. 8. Cadde, Boypas Blok No:3/A
Basaksehir, Istanbul, Turkey

Compliance Statement No. 0473-3P-1231091

This type of Class EA / Category 6A Screened Two Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6A electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples, consisting of the listed components. The tested channel is part of a 3P maintenance programme, with continuous verification of the electrical performance. The Compliance Statement is valid until 18 April 2026.

Cables:	<i>Horizontal Cable 5 m - 90 m,</i>	<i>Screened Cat. 8 (P/N see annex 1)</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
Conn. Hardware:	<i>Modular Jack,</i>	<i>Screened Connection Module Cat. 8 (P/N see annex 1)</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
Patch and equipment Cords:	<i>2 m,</i>	<i>Screened Cat. 8 Cord (P/N see annex 1)</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>


Hoersholm, 18 October 2023


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

www.3Ptest.dk

Hoersholm, 18 October 2023


Jens Rytter Petersen
General Manager

