Compliance Statement

Unscreened Category 5e
ISO/IEC, EN & ANSI/TIA
Communication Cable

R&M Freenet, Types R35045 and R35292

Cat. 5e, Overall Unscreened Cable with Unscreened Twisted Pairs
100 Ω, 4 Twisted Pairs, 24 AWG, Flame Retardant, LSHF, Copper Communication Cable

Reichle & De-Massari AG
Binzstrasse 32,
CH-8620 Wetzikon, Switzerland

Compliance Statement No. 0019-3P-2026-891

This Unscreened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by FORCE Technology under the 3P maintenance programme and complies with the Category 5 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 5e requirements of ANSI/TIA-568.2-E:2024, the requirements of CENELEC EN 50288-3-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to EN 60332-1-2 / IEC 60332-1-2, EN 61034-2 / IEC 61034-2 and EN 60754-2 / IEC 60754-2. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 9 June 2027.

Hoersholm, 9 June 2026

Peter Freiberg Kaas
Senior Specialist, Test Manager

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
https://www.3ptest.dk/

Hoersholm, 9 June 2026

Lars Lindskov Pedersen
Senior Team Leader, Test Manager