FORCE Technology

# Compliance Statement

## Unscreened Category 6
## ISO/IEC, EN & ANSI/TIA
## Communication Cable

### Premium Line Identification P/N 2061421xy

**Cat. 6, Overall Unscreened Cable with Unscreened Twisted Pairs**
**100 Ω, 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Communication Cable**

### Premium-Line Systems GmbH
### Rosenheimer Strasse 89,
### 83064 Raubling, Germany

***Compliance Statement No. 0019-3P-2026-1387***

*This Unscreened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by Force Technology under the 3P maintenance programme and complies with the Category 6 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6 requirements of ANSI/TIA-568.2-E:2024, the requirements of CENELEC EN 50288-6-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to EN 60332-1-2 / IEC 60332-1-2, EN 61034-2 / IEC 61034-2 and EN 60754-2 / IEC 60754-2. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 31 August 2027.*

Hoersholm, 31 August 2026

Peter Freiberg Kaas
Senior Specialist, Test Manager

**Force Technology**
**Venlighedsvej 4**
**2970 Hørsholm**
**Denmark**
**Tel. +45 43 25 14 00**
**https://www.3ptest.dk/**

Hoersholm, 31 August 2026

Lars Lindskov Pedersen
Senior Team Leader, Test Manager