



Compliance Statement

Screened Category 6A ISO/IEC, EN & ANSI/TIA Communication Cable

Asiawire Identification P/N AW-1001-0101-XXSFALZ
Cat. 6A, Overall Braid Screened Cable with Foil Screened Twisted Pairs
100 Ω , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Communication Cable

Asiawire International Co., Ltd.
No.1063, Sec,2 Huanzhong Rd., Xitun Dist.,
40760 Taichung City, Taiwan, R.O.C.

Compliance Statement No. 0019-3P-2026-1555

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by Force Technology under the 3P maintenance programme and complies with the Category 6A performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of ANSI/TIA-568.2-E:2024, the requirements of CENELEC EN 50288-10-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to EN 60332-1-2 / IEC 60332-1-2, EN 61034-2 / IEC 61034-2 and EN 60754-2 / IEC 60754-2. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 29 September 2027.

Hoersholm, 29 September 2026

Peter Freiberg Kaas
Senior Specialist, Test Manager

Force Technology
Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 43 25 14 00
<https://www.3ptest.dk/>

Hoersholm, 29 September 2026

Lars Lindskov Pedersen
Senior Team Leader, Test Manager