FORCE Technology

Compliance Statement

Screened Category 6
ISO/IEC, EN & ANSI/TIA
Communication Cable

YFC-BonEagle Identification P/N YLC-6PH04-CR-XXXXX

Cat. 6, Overall Braid Screened Cable with Foil Screened Twisted Pairs
100 Ω, 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Communication Cable

YFC-BonEagle Electric Co., Ltd.
No. 12-9, 130th Lane, Section 2, Chung Shan E. Road,
Hsinwu, Taoyuan, Taiwan, R.O.C.

Compliance Statement No. 0019-3P-2026-1560

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by Force Technology under the 3P maintenance programme and complies with the Category 6 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6 requirements of ANSI/TIA-568.2-E:2024, the requirements of CENELEC EN 50288-5-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to EN 60332-1-2 / IEC 60332-1-2, EN 61034-2 / IEC 61034-2 and EN 60754-2 / IEC 60754-2. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 29 September 2027.

Hoersholm, 29 September 2026

Peter Freiberg Kaas
Senior Specialist, Test Manager

Force Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
https://www.3ptest.dk/

Hoersholm, 29 September 2026

Lars Lindskov Pedersen
Senior Team Leader, Test Manager